



2 Liberty Sq., 6th Floor
Boston, MA 02109

T 617.350.3444
TRCcompanies.com

Asbestos Abatement Air Sampling Report

L Street Station Project
Boston, Massachusetts

Prepared for HRP 776 Summer Street, LLC
November 2023

ASBESTOS ABATEMENT AIR SAMPLING REPORT

L STREET STATION PROJECT

November 2023

1.0 INTRODUCTION

TRC Environmental, Inc. (TRC) has prepared this Air Sampling Report on behalf of HRP 776 Summer Street, LLC (the Client) for the deconstruction phase of the L Street Station project at 776 Summer Street in Boston, Massachusetts (the Site).

The air sampling is as described and in accordance with the requirements of the Non-Traditional Work Plan (NTWP) in place for the project, as approved by MassDEP (NTWP Approval NNT-220007). Pursuant to the NTWP, on a daily basis, TRC provides air sampling during asbestos abatement around the perimeter of the asbestos removal work areas, and as required for final air clearance at the completion of asbestos removal in contained work areas. Sample results are emailed to MassDEP at the end of the shift.

The air samples are analyzed by TRC's Asbestos Project Monitor after collection, typically twice per shift, in accordance with the Phase Contrast Microscopy (PCM) method. The results for each sample are then recorded in fibers per cubic centimeter of air (f/cc) on the air sampling data sheet. These air sample results and data sheets are attached to this report.



This report provides the air sampling results collected at the Site from the beginning of the abatement monitoring on November 1, through 30, 2023. Pursuant to the NTWP approved by DEP, the air sampling action level is < 0.010 f/cc. All air sample collected at the containment perimeter barriers, by TRC in connection with this work have been less than 0.010 f/cc throughout this time period.

2.0 DESCRIPTION OF SITE CONDITIONS

The Site previously operated as an electrical power plant. With the exception of one building, referred to as the Administration Office Building, the Site is vacant.

The Site is located in an urban area of South Boston and is bounded on all sides by roads.

3.0 AIR SAMPLING ACTION LEVELS

The action level required for this project for PCM air samples during abatement, as established in the NTWP, is less than 0.010 f/cc. If this level is reached or exceeded, asbestos abatement work is stopped, the MassDEP notified, and appropriate corrective measures taken. The level of 0.010 f/cc is also used for air clearance following abatement, to "clear" space for use prior to disassembling containment. On occasion, typically for "clearing" a large work area where PCM air sampling may be impractical, the Transmission Electron Microscopy (TEM) method will be used, which has a clearance level of an average of less than 70 structures per square millimeter (s/mm). TEM results, if any, associated with clearing work areas will be included in this report.

4.0 AIR SAMPLING

Pursuant to the approved NTWP, all area air samples are collected using the same basic techniques. The air sampling pumps are calibrated using a primary or secondary standard. The sample cassette is set between 4 to 5 feet above the floor/ground and angled downward at a 45-degree angle. Samples are collected "open faced," meaning that the cap at the inlet end of the extension has been removed so the entire surface of the



filter is exposed to the air. Samples are typically collected over a 2-to-3-hour period. Pumps are post-calibrated and the before and after flow rates are averaged. Chain-Of-Custody forms are completed, and the samples are analyzed.

Air samples are usually grouped together for each work area, as per the NTWP. Some results are recorded as <LOD, meaning that the result for that sample is below the limit of detection for the method (typically less than 0.002 f/cc, which is well below the action level).

5.0 CORRECTIVE MEASURES

No corrective measures were required November 1, through November 30, 2023, because all air sample results were below the action level.

ATTACHMENTS


Air sample results

ASBESTOS AIR SAMPLE RESULTS

Project Name	776 Summer Street (#3 Amendment Area 3)(Power Plant)	Sample Date	11/01/2023
TRC Project #	474824	Sampling Technician	David Adams
Client	HRP 776 Summer Street PropCo LLC	Laboratory	TRC
Facility Name	Building 3 Footprint	Sample/Analysis Method	NIOSH 7400
Facility Location	776 Summer Street, Boston, Massachusetts	Sampling Type	PCM

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Clearance	003	South area inside containment at HEPA unit	07:24	09:05	101	12	12	12	1212	1.5	100	0.002	<LOD	N/A
Clearance	004	North area inside containment at decon	07:25	09:06	101	12	12	12	1212	3	100	0.002	<LOD	N/A
Field Blank	001	Field Blank 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A
Field Blank	002	Field Blank 2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A

Analysis Information

Analyst	David Adams		
Analyst Signature		Analysis Date	11/01/2023

ASBESTOS AIR SAMPLE RESULTS

Project Name	776 Summer Street (#7 Amendment - Level 12 East)(Power Plant)	Sample Date	11/01/2023
TRC Project #	474824	Sampling Technician	David Adams
Client	HRP 776 Summer Street PropCo LLC	Laboratory	TRC
Facility Name	Building 4	Sample/Analysis Method	NIOSH 7400
Facility Location	776 Summer Street, Boston, Massachusetts	Sampling Type	PCM

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	003	7 - east wall - level 12	07:38	10:40	182	8	8	8	1456	4.5	100	0.002	0.002	N/A
Clearance	004	7 - southeast corner of South wall - level 12	07:39	10:41	182	8	8	8	1456	2.5	100	0.002	<LOD	N/A
Area	005	7 - center of Southeast area wall - level 12	07:40	10:42	182	8	8	8	1456	5	100	0.002	0.002	N/A
Area	006	7 - southwest area of South wall at center stairwell - level 12	07:41	10:43	182	8	8	8	1456	3	100	0.002	<LOD	N/A
Area	007	7 - southeast corner of South wall - level 12	10:40	13:45	185	8	8	8	1480	3.5	100	0.002	<LOD	N/A
Area	008	7 - southeast corner of South wall - level 12	10:41	13:46	185	8	8	8	1480	2	100	0.002	<LOD	N/A
Area	009	7 - center of Southeast area wall - level 12	10:42	13:47	185	8	8	8	1480	4.5	100	0.002	<LOD	N/A

ASBESTOS AIR SAMPLE RESULTS

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	010	7 - southwest area of South wall at center stairwell - level 12	10:43	13:48	185	8	8	8	1480	2.5	100	0.002	<LOD	N/A
Field Blank	001	Field Blank 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A
Field Blank	002	Field Blank 2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A

Analysis Information

Analyst	David Adams	Analysis Date	11/01/2023
Analyst Signature	<i>DA AL</i>		

ASBESTOS AIR SAMPLE RESULTS

Project Name	776 Summer Street (#7 Amendment Level 11 West)(Power Plant)	Sample Date	11/02/2023
TRC Project #	474824	Sampling Technician	David Adams
Client	HRP 776 Summer Street PropCo LLC	Laboratory	TRC
Facility Name	Building 4	Sample/Analysis Method	NIOSH 7400
Facility Location	776 Summer Street, Boston, Massachusetts	Sampling Type	PCM

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	003	7 - east wall adjacent to stairway - level 11	08:18	10:57	159	8	8	8	1272	5.5	100	0.002	0.002	N/A
Area	004	7 - southeast area of South wall - level 11	08:19	10:58	159	8	8	8	1272	2	100	0.002	<LOD	N/A
Area	005	7 - southwest area of South wall - level 12	08:20	10:59	159	8	8	8	1272	5	100	0.002	0.002	N/A
Area	006	7 - west wall level 11	08:21	11:00	159	8	8	8	1272	6	100	0.002	0.002	N/A
Area	007	7 - east wall adjacent to stairway - level 11	10:57	13:55	178	8	8	8	1424	3	100	0.002	<LOD	N/A
Area	008	7 - southeast area of South wall - level 11	10:58	13:56	178	8	8	8	1424	1.5	100	0.002	<LOD	N/A
Area	009	7 - southwest area of South wall - level 12	10:59	13:57	178	8	8	8	1424	3	100	0.002	<LOD	N/A
Area	010	7 - west wall level 11	11:00	13:58	178	8	8	8	1424	3.5	100	0.002	<LOD	N/A

ASBESTOS AIR SAMPLE RESULTS

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Field Blank	001	Field Blank 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A
Field Blank	002	Field Blank 2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A

Analysis Information

Analyst	David Adams	Analysis Date	11/02/2023
Analyst Signature	<i>DA AL</i>		

ASBESTOS AIR SAMPLE RESULTS


Project Name	776 Summer Street (#3 Amendment Area 4)(Power Plant)	Sample Date	11/02/2023
TRC Project #	474824	Sampling Technician	David Adams
Client	HRP 776 Summer Street PropCo LLC	Laboratory	TRC
Facility Name	Building 3 Footprint	Sample/Analysis Method	NIOSH 7400
Facility Location	776 Summer Street, Boston, Massachusetts	Sampling Type	PCM

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	003	3 - northwest area of containment on sidewalk	11:25	14:10	165	8	8	8	1320	5.5	100	0.002	0.002	N/A
Area	004	3 - southwest area of containment on sidewalk	11:26	14:11	165	8	8	8	1320	4	100	0.002	<LOD	N/A
Area	005	3 - southeast area of containment at decon	11:27	14:12	165	8	8	8	1320	2	100	0.002	<LOD	N/A
Area	006	3 - northeast area of containment at hepa exhaust	11:28	14:13	165	8	8	8	1320	3.5	100	0.002	<LOD	N/A

ASBESTOS AIR SAMPLE RESULTS

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Field Blank	001	Field Blank 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A
Field Blank	002	Field Blank 2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A

Analysis Information


Analyst	David Adams	Analysis Date	11/02/2023
Analyst Signature			

ASBESTOS AIR SAMPLE RESULTS

Project Name	776 Summer Street (#3 Amendment - Area 4)(Power Plant)	Sample Date	11/06/2023
TRC Project #	474824	Sampling Technician	David Adams
Client	HRP 776 Summer Street PropCo LLC	Laboratory	TRC
Facility Name	Building 3 Footprint	Sample/Analysis Method	NIOSH 7400
Facility Location	776 Summer Street, Boston, Massachusetts	Sampling Type	PCM

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Clearance	003	North are inside containment adjacent hepa unit	07:00	08:45	105	12	12	12	1260	3.5	100	0.002	<LOD	N/A
Clearance	004	South area inside containment at decon entrance	07:01	08:46	105	12	12	12	1260	2	100	0.002	<LOD	N/A
Field Blank	001	Field Blank 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A
Field Blank	002	Field Blank 2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A

Analysis Information

Analyst	David Adams	Analysis Date	11/06/2023
Analyst Signature			

ASBESTOS AIR SAMPLE RESULTS


Project Name	776 Summer Street (#3 Amendment - Area 5)(Power Plant)	Sample Date	11/07/2023
TRC Project #	474824	Sampling Technician	David Adams
Client	HRP 776 Summer Street PropCo LLC	Laboratory	TRC
Facility Name	Building 3 Footprint	Sample/Analysis Method	NIOSH 7400
Facility Location	776 Summer Street, Boston, Massachusetts	Sampling Type	PCM

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	003	3 - northwest area of containment on sidewalk	08:30	11:05	155	8	8	8	1240	5	100	0.002	<LOD	N/A
Area	004	3 - southwest area of containment on sidewalk	08:31	11:06	155	8	8	8	1240	4.5	100	0.002	<LOD	N/A
Area	005	3 - southeast area of containment at decon	08:32	11:07	155	8	8	8	1240	3	100	0.002	<LOD	N/A
Area	006	3 - northeast area of containment at hepa exhaust	08:33	11:08	155	8	8	8	1240	5	100	0.002	<LOD	N/A
Area	007	3 - northwest area of containment on sidewalk	11:05	13:50	165	8	8	8	1320	4	100	0.002	<LOD	N/A
Area	008	3 - southwest area of containment on sidewalk	11:06	14:11	185	8	8	8	1480	3.5	100	0.002	<LOD	N/A
Area	009	3 - southeast area of containment at decon	11:07	14:12	185	8	8	8	1480	3.4	100	0.002	<LOD	N/A

ASBESTOS AIR SAMPLE RESULTS

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	010	3 - northeast area of containment at hepa exhaust	11:08	14:13	185	8	8	8	1480	6	100	0.002	<LOD	N/A
Field Blank	001	Field Blank 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	8	100	N/A	N/A	N/A
Field Blank	002	Field Blank 2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A

Analysis Information

Analyst	David Adams	Analysis Date	11/07/2023
Analyst Signature			

ASBESTOS AIR SAMPLE RESULTS

Project Name		776 Summer Street (#3 Amendment - Area 5)(Power Plant)					Sample Date		11/08/2023					
TRC Project #		474824					Sampling Technician		David Adams					
Client		HRP 776 Summer Street PropCo LLC					Laboratory		TRC					
Facility Name		Building 3 Footprint					Sample/Analysis Method		NIOSH 7400					
Facility Location		776 Summer Street, Boston, Massachusetts					Sampling Type		PCM					
Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	003	3 - northwest area of containment on sidewalk	07:25	10:10	165	8	8	8	1320	3.5	100	0.002	<LOD	N/A
Area	004	3 - southwest area of containment on sidewalk	07:26	10:11	165	8	8	8	1320	5.5	100	0.002	0.002	N/A
Area	005	3 - southeast area of containment at decon	07:27	10:12	165	8	8	8	1320	4	100	0.002	<LOD	N/A
Area	006	3 - northeast area of containment at hepa exhaust	07:28	10:13	165	8	8	8	1320	3	100	0.002	<LOD	N/A
Clearance	007	North area inside containment adjacent hepa unit	10:30	12:15	105	12	12	12	1260	2.5	100	0.002	<LOD	N/A
Clearance	008	South area inside containment adjacent decon	10:31	12:16	105	12	12	12	1260	1.5	100	0.002	<LOD	N/A

ASBESTOS AIR SAMPLE RESULTS

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Field Blank	001	Field Blank 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A
Field Blank	002	Field Blank 2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A

Analysis Information

Analyst	David Adams	Analysis Date	11/08/2023
Analyst Signature	DAAL		


ASBESTOS AIR SAMPLE RESULTS

Project Name		776 Summer Street (#7 Amendment - East Area Level 11)(Power Plant)					Sample Date		11/06/2023					
TRC Project #		474824					Sampling Technician		David Adams					
Client		HRP 776 Summer Street PropCo LLC					Laboratory		TRC					
Facility Name		Building 4					Sample/Analysis Method		NIOSH 7400					
Facility Location		776 Summer Street, Boston, Massachusetts					Sampling Type		PCM					
Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	003	7 - decon on ground level, west wall	07:35	10:30	175	8	8	8	1400	5	100	0.002	0.002	N/A
Area	004	7 - northwest corner , ground level of remaining building	07:36	10:31	175	8	8	8	1400	4.5	100	0.002	0.002	N/A
Area	005	7 - loadout on ground level	07:38	10:33	175	8	8	8	1400	3	100	0.002	<LOD	N/A
Area	006	7 - TH3 decon	07:46	10:40	174	8	8	8	1392	2.5	100	0.002	<LOD	N/A
Area	007	7 - east wall adjacent to stairway - level 11	07:50	10:45	175	8	8	8	1400	2	100	0.002	<LOD	N/A
Area	008	7 - southeast area of South wall - level 11	07:51	10:46	175	8	8	8	1400	3	100	0.002	<LOD	N/A
Area	009	7 - southwest area of South wall - level 11	07:52	10:47	175	8	8	8	1400	5.5	100	0.002	0.002	N/A
Area	010	7 - west wall level 11	07:55	10:50	175	8	8	8	1400	4	100	0.002	<LOD	N/A
Area	011	7 - decon on ground level, west wall	10:30	13:34	184	8	8	8	1472	3	100	0.002	<LOD	N/A

ASBESTOS AIR SAMPLE RESULTS

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	012	7 - northwest corner , ground level of remaining building	10:31	13:35	184	8	8	8	1472	3.5	100	0.002	<LOD	N/A
Area	013	7 - loadout on ground level	10:33	13:37	184	8	8	8	1472	2.5	100	0.002	<LOD	N/A
Area	014	7 - TH3 decon	10:40	13:44	184	8	8	8	1472	4	100	0.002	<LOD	N/A
Area	015	7 - east wall adjacent to stairway - level 11	10:45	13:49	184	8	8	8	1472	2.5	100	0.002	<LOD	N/A
Area	016	7 - southeast area of South wall - level 11	10:46	13:50	184	8	8	8	1472	4	100	0.002	<LOD	N/A
Area	017	7 - southwest area of South wall - level 11	10:47	13:51	184	8	8	8	1472	6.5	100	0.002	0.002	N/A
Area	018	7 - west wall level 11	10:50	13:55	185	8	8	8	1480	5	100	0.002	0.002	N/A
Field Blank	001	Field Blank 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A
Field Blank	002	Field Blank 2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A

Analysis Information

Analyst	David Adams	Analysis Date	11/06/2023
Analyst Signature			

ASBESTOS AIR SAMPLE RESULTS


Project Name	776 Summer Street (#7 Amendment - East Area Level 11)(Power Plant)	Sample Date	11/07/2023
TRC Project #	474824	Sampling Technician	David Adams
Client	HRP 776 Summer Street PropCo LLC	Laboratory	TRC
Facility Name	Building 4	Sample/Analysis Method	NIOSH 7400
Facility Location	776 Summer Street, Boston, Massachusetts	Sampling Type	PCM

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	003	7 - decon on ground level, west wall	07:25	10:30	185	8	8	8	1480	3	100	0.002	<LOD	N/A
Area	004	7 - northwest corner , ground level of remaining building	07:26	10:31	185	8	8	8	1480	5	100	0.002	0.002	N/A
Area	005	7 - loadout on ground level	07:28	10:33	185	8	8	8	1480	3.5	100	0.002	<LOD	N/A
Area	006	TH3 decon	07:36	10:40	184	8	8	8	1472	2.5	100	0.002	<LOD	N/A
Area	007	7 - east wall adjacent to stairway - level 11	07:41	10:45	184	8	8	8	1472	3	100	0.002	<LOD	N/A
Area	008	7 - southeast area of South wall - level 11	07:42	10:46	184	8	8	8	1472	3	100	0.002	<LOD	N/A
Area	009	7 - southwest area of South wall - level 11	07:43	10:47	184	8	8	8	1472	5.5	100	0.002	0.002	N/A
Area	010	7 - west wall level 11	07:44	10:48	184	8	8	8	1472	2	100	0.002	<LOD	N/A
Area	011	7 - decon on ground level, west wall	10:30	14:05	215	8	8	8	1720	4.5	100	0.002	<LOD	N/A

ASBESTOS AIR SAMPLE RESULTS

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	012	7 - northwest corner , ground level of remaining building	10:31	14:06	215	8	8	8	1720	7	100	0.002	0.002	N/A
Area	013	7 - loadout on ground level	10:33	14:08	215	8	8	8	1720	5	100	0.002	<LOD	N/A
Area	014	TH3 decon	10:40	14:20	220	8	8	8	1760	2	100	0.002	<LOD	N/A
Area	015	7 - east wall adjacent to stairway - level 11	10:45	14:26	221	8	8	8	1768	4	100	0.002	<LOD	N/A
Area	016	7 - southeast area of South wall - level 11	10:46	14:27	221	8	8	8	1768	5	100	0.002	<LOD	N/A
Area	017	7 - southwest area of South wall - level 11	10:47	14:28	221	8	8	8	1768	4.5	100	0.002	<LOD	N/A
Area	018	7 - west wall level 11	10:48	14:29	221	8	8	8	1768	3.5	100	0.002	<LOD	N/A
Field Blank	001	Field Blank 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A
Field Blank	002	Field Blank 2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A

Analysis Information

Analyst	David Adams	Analysis Date	11/07/2023
Analyst Signature			

ASBESTOS AIR SAMPLE RESULTS


Project Name	776 Summer Street (#7 Amendment – East Area Level 11)(Power Plant)	Sample Date	11/08/2023
TRC Project #	474824	Sampling Technician	David Adams
Client	HRP 776 Summer Street PropCo LLC	Laboratory	TRC
Facility Name	Building 4	Sample/Analysis Method	NIOSH 7400
Facility Location	776 Summer Street, Boston, Massachusetts	Sampling Type	PCM

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	003	7 - decon on ground level, west wall	07:31	10:36	185	8	8	8	1480	4.5	100	0.002	<LOD	N/A
Area	004	7 - northwest corner , ground level of remaining building	07:34	10:40	186	8	8	8	1488	4	100	0.002	<LOD	N/A
Area	005	7 - loadout on ground level	07:35	10:41	186	8	8	8	1488	6.5	100	0.002	0.002	N/A
Area	006	7 - TH3 decon	07:42	10:49	187	8	8	8	1496	3.5	100	0.002	<LOD	N/A
Area	007	7 - east wall adjacent to stairway - level 11	07:47	10:55	188	8	8	8	1504	5	100	0.002	0.002	N/A
Area	008	7 - southeast corner area of South wall - level 11	07:48	10:56	188	8	8	8	1504	4.5	100	0.002	<LOD	N/A
Area	009	7 - southwest area of South wall - level 11	07:49	10:57	188	8	8	8	1504	2	100	0.002	<LOD	N/A
Area	010	7 - center stairwell level 11	07:50	10:58	188	8	8	8	1504	2.5	100	0.002	<LOD	N/A
Area	011	7 - decon on ground level, west wall	10:36	13:35	179	8	8	8	1432	3	100	0.002	<LOD	N/A

ASBESTOS AIR SAMPLE RESULTS

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	012	7 - northwest corner , ground level of remaining building	10:40	13:38	178	8	8	8	1424	4	100	0.002	<LOD	N/A
Area	013	7 - loadout on ground level	10:41	13:39	178	8	8	8	1424	5	100	0.002	0.002	N/A
Area	014	TH3 decon	10:49	13:48	179	8	8	8	1432	2.5	100	0.002	<LOD	N/A
Area	015	7 - east wall adjacent to stairway - level 11	10:55	13:53	178	8	8	8	1424	3.5	100	0.002	<LOD	N/A
Area	016	7 - southeast corner area of South wall - level 11	10:56	13:54	178	8	8	8	1424	2.5	100	0.002	<LOD	N/A
Area	017	7 - southwest area of South wall - level 11	10:57	13:55	178	8	8	8	1424	2	100	0.002	<LOD	N/A
Area	018	7 - center stairwell level 11	10:58	13:56	178	8	8	8	1424	4.5	100	0.002	0.002	N/A
Field Blank	001	Field Blank 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A
Field Blank	002	Field Blank 2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A

Analysis Information

Analyst	David Adams	Analysis Date	11/08/2023
Analyst Signature			


ASBESTOS AIR SAMPLE RESULTS

Project Name	776 Summer Street (#7 Amendment - East Area Level 11)(Power Plant)	Sample Date	11/09/2023
TRC Project #	474824	Sampling Technician	David Adams
Client	HRP 776 Summer Street PropCo LLC	Laboratory	TRC
Facility Name	Building 4	Sample/Analysis Method	NIOSH 7400
Facility Location	776 Summer Street, Boston, Massachusetts	Sampling Type	PCM

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	003	7 - decon on ground level, west wall	07:48	10:50	182	8	8	8	1456	2	100	0.002	<LOD	N/A
Area	004	7 - northwest corner , ground level of remaining building	07:54	10:53	179	8	8	8	1432	4.5	100	0.002	0.002	N/A
Area	005	7 - loadout on ground level	07:55	10:54	179	8	8	8	1432	5.5	100	0.002	0.002	N/A
Area	006	Turbine Hall 3 roof at decon	08:02	11:00	178	8	8	8	1424	1.5	100	0.002	<LOD	N/A
Area	007	7 - east wall adjacent to stairway - level 11	08:07	11:06	179	8	8	8	1432	2	100	0.002	<LOD	N/A
Area	008	7 - southeast corner area of South wall - level 11	08:08	11:07	179	8	8	8	1432	1.5	100	0.002	<LOD	N/A
Area	009	7 - southwest area of South wall - level 11	08:09	11:08	179	8	8	8	1432	2.5	100	0.002	<LOD	N/A
Area	010	7 - center stairwell level 11	08:10	11:09	179	8	8	8	1432	2	100	0.002	<LOD	N/A
Area	011	7 - decon on ground level, west wall	10:50	14:30	220	8	8	8	1760	1.5	100	0.002	<LOD	N/A

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	012	7 - northwest corner , ground level of remaining building	10:53	14:32	219	8	8	8	1752	3	100	0.002	<LOD	N/A
Area	013	7 - loadout on ground level	10:54	14:33	219	8	8	8	1752	4.5	100	0.002	<LOD	N/A
Area	014	Turbine Hall 3 roof at decon	11:00	14:40	220	8	8	8	1760	2	100	0.002	<LOD	N/A
Area	015	7 - east wall adjacent to stairway - level 11	11:06	14:44	218	8	8	8	1744	2.5	100	0.002	<LOD	N/A
Area	016	7 - southeast corner area of South wall - level 11	11:06	14:44	218	8	8	8	1744	2.5	100	0.002	<LOD	N/A
Area	017	7 - southwest area of South wall - level 11	11:08	14:46	218	8	8	8	1744	1.5	100	0.002	<LOD	N/A
Area	018	7 - center stairwell level 11	11:09	14:47	218	8	8	8	1744	2	100	0.002	<LOD	N/A
Field Blank	001	Field Blank 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A
Field Blank	002	Field Blank 2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A

Analysis Information

Analyst	David Adams	Analysis Date	11/09/2023
Analyst Signature			


Project Name	776 Summer Street (#7 Amendment - East Area Level 11)(Power Plant)	Sample Date	11/10/2023
TRC Project #	474824	Sampling Technician	David Adams
Client	HRP 776 Summer Street PropCo LLC	Laboratory	TRC
Facility Name	Building 4	Sample/Analysis Method	NIOSH 7400
Facility Location	776 Summer Street, Boston, Massachusetts	Sampling Type	PCM

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	003	7 - decon on ground level, west wall	07:47	10:39	172	8	8	8	1376	3	100	0.002	<LOD	N/A
Area	004	7 - northwest corner , ground level of remaining building	07:48	10:42	174	8	8	8	1392	5	100	0.002	0.002	N/A
Area	005	7 - loadout on ground level	07:50	10:43	173	8	8	8	1384	6.5	100	0.002	0.002	N/A
Area	006	Turbine Hall 3 roof at decon	07:57	10:50	173	8	8	8	1384	2.5	100	0.002	<LOD	N/A
Area	007	7 - east wall adjacent to stairway - level 11	08:02	10:55	173	8	8	8	1384	4	100	0.002	<LOD	N/A
Area	008	7 - southeast corner area of South wall - level 11	08:03	10:56	173	8	8	8	1384	5	100	0.002	0.002	N/A
Area	009	7 - southwest area of South wall - level 11	08:04	10:57	173	8	8	8	1384	3.5	100	0.002	<LOD	N/A
Area	010	7 - center stairwell level 11	08:05	10:58	173	8	8	8	1384	2	100	0.002	<LOD	N/A
Area	011	7 - decon on ground level, west wall	10:39	13:35	176	8	8	8	1408	4.5	100	0.002	0.002	N/A

ASBESTOS AIR SAMPLE RESULTS

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	012	7 - northwest corner , ground level of remaining building	10:42	13:37	175	8	8	8	1400	7	100	0.002	0.002	N/A
Area	013	7 - loadout on ground level	10:43	13:38	175	8	8	8	1400	6.5	100	0.002	0.002	N/A
Area	014	Turbine Hall 3 roof at decon	10:50	13:44	174	8	8	8	1392	3	100	0.002	<LOD	N/A
Area	015	7 - east wall adjacent to stairway - level 11	10:55	13:49	174	8	8	8	1392	2.5	100	0.002	<LOD	N/A
Area	016	7 - southeast corner area of South wall - level 11	10:56	13:50	174	8	8	8	1392	2	100	0.002	<LOD	N/A
Area	017	7 - southwest area of South wall - level 11	10:57	13:51	174	8	8	8	1392	2.5	100	0.002	<LOD	N/A
Area	018	7 - center stairwell level 11	10:58	13:52	174	8	8	8	1392	2.5	100	0.002	<LOD	N/A
Field Blank	001	Field Blank 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A
Field Blank	002	Field Blank 2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A

Analysis Information

Analyst	David Adams	Analysis Date	11/10/2023
Analyst Signature			

ASBESTOS AIR SAMPLE RESULTS


Project Name	776 Summer Street (#3 Amendment - Area 6)(Power Plant)	Sample Date	11/09/2023
TRC Project #	474824	Sampling Technician	David Adams
Client	HRP 776 Summer Street PropCo LLC	Laboratory	TRC
Facility Name	Building 3 Footprint	Sample/Analysis Method	NIOSH 7400
Facility Location	776 Summer Street, Boston, Massachusetts	Sampling Type	PCM

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	003	3 - northwest area of containment on sidewalk	07:25	10:08	163	8	8	8	1304	2	100	0.002	<LOD	N/A
Area	004	3 - southwest area of containment on sidewalk	07:26	10:09	163	8	8	8	1304	1.5	100	0.002	<LOD	N/A
Area	005	3 - southeast area of containment at hepa exhaust	07:27	10:10	163	8	8	8	1304	1.5	100	0.002	<LOD	N/A
Area	006	3 - northeast area of containment at decon entrance	07:28	10:11	163	8	8	8	1304	2.5	100	0.002	<LOD	N/A
Clearance	007	South area inside containment adjacent hepa unit	10:23	12:05	102	12	12	12	1224	1	100	0.002	<LOD	N/A
Clearance	008	North area inside containment adjacent decon	10:24	12:06	102	12	12	12	1224	2.5	100	0.002	<LOD	N/A

ASBESTOS AIR SAMPLE RESULTS

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Field Blank	001	Field Blank 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A
Field Blank	002	Field Blank 2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A

Analysis Information

Analyst	David Adams	Analysis Date	11/09/2023
Analyst Signature			

ASBESTOS AIR SAMPLE RESULTS


Project Name	776 Summer Street (#3 Amendment Area 7)(Power Plant)	Sample Date	11/10/2023
TRC Project #	474824	Sampling Technician	David Adams
Client	HRP 776 Summer Street PropCo LLC	Laboratory	TRC
Facility Name	Building 3 Footprint	Sample/Analysis Method	NIOSH 7400
Facility Location	776 Summer Street, Boston, Massachusetts	Sampling Type	PCM

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	003	3 - northwest area of containment on sidewalk	07:17	10:00	163	8	8	8	1304	4.5	100	0.002	0.002	N/A
Area	004	3 - southwest area of containment on sidewalk	07:18	10:01	163	8	8	8	1304	5	100	0.002	0.002	N/A
Area	005	3 - southeast area of containment at decon	07:19	10:02	163	8	8	8	1304	3.5	100	0.002	<LOD	N/A
Area	006	3 - northeast area of containment at hepa exhaust	07:20	10:03	163	8	8	8	1304	4	100	0.002	0.002	N/A
Clearance	007	North area inside containment adjacent hepa unit	10:19	11:45	86	14	14	14	1204	3	100	0.002	<LOD	N/A
Clearance	008	South area inside containment at decon equipment room	10:20	11:46	86	14	14	14	1204	2	100	0.002	<LOD	N/A

ASBESTOS AIR SAMPLE RESULTS

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Field Blank	001	Field Blank 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A
Field Blank	002	Field Blank 2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A

Analysis Information

Analyst	David Adams	Analysis Date	11/10/2023
Analyst Signature			


ASBESTOS AIR SAMPLE RESULTS

Project Name	776 Summer Street (#7 Amendment - Level 10 - West, East & South)(Power Plant)	Sample Date	11/13/2023
TRC Project #	474824	Sampling Technician	David Adams
Client	HRP 776 Summer Street PropCo LLC	Laboratory	TRC
Facility Name	Building 4 South Wall	Sample/Analysis Method	NIOSH 7400
Facility Location	776 Summer Street, Boston, Massachusetts	Sampling Type	PCM

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	003	7 - decon on ground level, west wall	07:25	10:25	180	8	8	8	1440	3	100	0.002	<LOD	N/A
Area	004	7 - northwest corner , ground level of remaining building	07:27	10:29	182	8	8	8	1456	6	100	0.002	0.002	N/A
Area	005	7 - loadout on ground level	07:28	10:28	180	8	8	8	1440	6.5	100	0.002	0.002	N/A
Area	006	7 - Turbine Hall 3 roof at decon	07:34	10:35	181	8	8	8	1448	2.5	100	0.002	<LOD	N/A
Area	007	7 - east area adjacent east wall stairs - level 10	07:40	10:40	180	8	8	8	1440	4.5	100	0.002	0.002	N/A
Area	008	7 - southeast area of South wall - level 10	07:41	10:41	180	8	8	8	1440	4.5	100	0.002	0.002	N/A
Area	009	7 - southwest area of South wall - level 10	07:42	10:42	180	8	8	8	1440	4	100	0.002	<LOD	N/A
Area	010	7 - west wall level 10	07:43	10:43	180	8	8	8	1440	2.5	100	0.002	<LOD	N/A
Area	011	7 - decon on ground level, west wall	11:20	13:51	151	8	8	8	1208	4.5	100	0.002	0.002	N/A

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	012	7 - northwest corner , ground level of remaining building	11:22	13:53	151	8	8	8	1208	4	100	0.002	0.002	N/A
Area	013	7 - loadout on ground level	11:23	13:54	151	8	8	8	1208	5.5	100	0.002	0.002	N/A
Area	014	7 - Turbine Hall 3 roof at decon	11:29	14:00	151	8	8	8	1208	3.5	100	0.002	<LOD	N/A
Area	015	7 - east area adjacent east wall stairs - level 10	11:34	14:05	151	8	8	8	1208	5	100	0.002	0.002	N/A
Area	016	7 - southeast area of South wall - level 10	11:35	14:06	151	8	8	8	1208	4.5	100	0.002	0.002	N/A
Area	017	7 - southwest area of South wall - level 10	11:36	14:07	151	8	8	8	1208	2	100	0.002	<LOD	N/A
Area	018	7 - west wall level 10	11:37	14:08	151	8	8	8	1208	4.5	100	0.002	0.002	N/A
Field Blank	001	Field Blank 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A
Field Blank	002	Field Blank 2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A

Analysis Information

Analyst	David Adams	Analysis Date	11/13/2023
Analyst Signature			


ASBESTOS AIR SAMPLE RESULTS

Project Name	776 Summer Street (#7 Amendment - Level 10 - West, East & South)(Power Plant)	Sample Date	11/14/2023
TRC Project #	474824	Sampling Technician	David Adams
Client	HRP 776 Summer Street PropCo LLC	Laboratory	TRC
Facility Name	Building 4 South Wall	Sample/Analysis Method	NIOSH 7400
Facility Location	776 Summer Street, Boston, Massachusetts	Sampling Type	PCM

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	003	7 - decon on ground level, west wall	07:20	11:05	225	8	8	8	1800	4.5	100	0.001	0.001	N/A
Area	004	7 - northwest corner , ground level of remaining building	07:22	11:07	225	8	8	8	1800	3	100	0.001	0.001	N/A
Area	005	7 - loadout on ground level	07:23	11:08	225	8	8	8	1800	5	100	0.001	0.001	N/A
Area	006	7 - Turbine Hall 3 roof at decon	07:29	11:14	225	8	8	8	1800	2.5	100	0.001	0.001	N/A
Area	007	7 - east area adjacent east wall stairs - level 10	07:34	11:19	225	8	8	8	1800	3.5	100	0.001	0.001	N/A
Area	008	7 - southeast area of South wall - level 10	07:35	11:20	225	8	8	8	1800	4.5	100	0.001	0.001	N/A
Area	009	7 - southwest area of South wall - level 10	07:36	11:21	225	8	8	8	1800	3	100	0.001	0.001	N/A
Area	010	7 - west wall level 10	07:37	11:22	225	8	8	8	1800	5	100	0.001	0.001	N/A
Area	011	7 - decon on ground level, west wall	11:20	13:52	152	8	8	8	1216	5.5	100	0.002	0.002	N/A

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	012	7 - northwest corner , ground level of remaining building	11:07	13:53	166	8	8	8	1328	6	100	0.002	0.002	N/A
Area	013	7 - loadout on ground level	11:08	13:54	166	8	8	8	1328	4	100	0.002	<LOD	N/A
Area	014	7 - Turbine Hall 3 roof at decon	11:14	14:01	167	8	8	8	1336	3.5	100	0.002	<LOD	N/A
Area	015	7 - east area adjacent east wall stairs - level 10	11:19	14:06	167	8	8	8	1336	3	100	0.002	<LOD	N/A
Area	016	7 - southeast area of South wall - level 10	11:20	14:07	167	8	8	8	1336	2.5	100	0.002	<LOD	N/A
Area	017	7 - southwest area of South wall - level 10	11:21	14:08	167	8	8	8	1336	6	100	0.002	0.002	N/A
Area	018	7 - west wall level 10	11:22	14:09	167	8	8	8	1336	5.5	100	0.002	0.002	N/A
Field Blank	001	Field Blank 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A
Field Blank	002	Field Blank 2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A

Analysis Information

Analyst	David Adams	Analysis Date	11/14/2023
Analyst Signature			

ASBESTOS AIR SAMPLE RESULTS


Project Name	776 Summer Street (#7 Amendment - Level 10 - West, East & South)(Power Plant)	Sample Date	11/15/2023
TRC Project #	474824	Sampling Technician	David Adams
Client	HRP 776 Summer Street PropCo LLC	Laboratory	TRC
Facility Name	Building 4 South Wall	Sample/Analysis Method	NIOSH 7400
Facility Location	776 Summer Street, Boston, Massachusetts	Sampling Type	PCM

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	003	7 - decon on ground level, west wall	07:17	09:05	108	12	12	12	1296	5.5	100	0.002	0.002	N/A
Area	004	7 - northwest corner , ground level of remaining building	07:19	09:07	108	12	12	12	1296	3	100	0.002	<LOD	N/A
Area	005	7 - loadout on ground level	07:20	09:08	108	12	12	12	1296	3.5	100	0.002	<LOD	N/A
Area	006	7 - Turbine Hall 3 roof at decon	07:26	09:14	108	12	12	12	1296	2.5	100	0.002	<LOD	N/A
Area	007	7 - east area adjacent east wall stairs - level 10	07:30	09:19	109	12	12	12	1308	4	100	0.002	<LOD	N/A
Area	008	7 - southeast area of South wall - level 10	07:31	09:20	109	12	12	12	1308	5	100	0.002	0.002	N/A
Area	009	7 - southwest area of South wall - level 10	07:32	09:21	109	12	12	12	1308	5.5	100	0.002	0.002	N/A
Area	010	7 - west wall level 10	07:33	09:22	109	12	12	12	1308	3	100	0.002	<LOD	N/A
Area	011	7 - decon on ground level, west wall	09:05	10:55	110	12	12	12	1320	6	100	0.002	0.002	N/A

ASBESTOS AIR SAMPLE RESULTS

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	012	7 - northwest corner , ground level of remaining building	09:07	10:57	110	12	12	12	1320	4	100	0.002	<LOD	N/A
Area	013	7 - loadout on ground level	09:08	10:58	110	12	12	12	1320	2.5	100	0.002	<LOD	N/A
Area	014	7 - Turbine Hall 3 roof at decon	09:14	11:04	110	12	12	12	1320	3	100	0.002	<LOD	N/A
Area	015	7 - east area adjacent east wall stairs - level 10	09:19	11:09	110	12	12	12	1320	3.5	100	0.002	<LOD	N/A
Area	016	7 - southeast area of South wall - level 10	09:20	11:10	110	12	12	12	1320	6	100	0.002	0.002	N/A
Area	017	7 - southwest area of South wall - level 10	09:21	11:11	110	12	12	12	1320	5	100	0.002	0.002	N/A
Area	018	7 - west wall level 10	09:22	11:12	110	12	12	12	1320	3	100	0.002	<LOD	N/A
Field Blank	001	Field Blank 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A
Field Blank	002	Field Blank 2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A

Analysis Information

Analyst	David Adams	Analysis Date	11/15/2023
Analyst Signature			

ASBESTOS AIR SAMPLE RESULTS


Project Name	776 Summer Street (#7 Amendment - Level 10 - West, East & South)(Power Plant)	Sample Date	11/16/2023
TRC Project #	474824	Sampling Technician	David Adams
Client	HRP 776 Summer Street PropCo LLC	Laboratory	TRC
Facility Name	Building 4 South Wall	Sample/Analysis Method	NIOSH 7400
Facility Location	776 Summer Street, Boston, Massachusetts	Sampling Type	PCM

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	003	7 - decon on ground level, west wall	07:28	11:05	217	8	8	8	1736	5	100	0.002	<LOD	N/A
Area	004	7 - northwest corner , ground level of remaining building	07:30	23:07	937	8	8	8	7496	3.5	100	0	0	N/A
Area	005	7 - loadout on ground level	07:31	11:08	217	8	8	8	1736	6	100	0.002	0.002	N/A
Area	006	7 - Turbine Hall 3 roof at decon	07:37	11:14	217	8	8	8	1736	2	100	0.002	<LOD	N/A
Area	007	7 - east area adjacent east wall stairs - level 10	07:42	11:19	217	8	8	8	1736	3	100	0.002	<LOD	N/A
Area	008	7 - southeast area of South wall - level 10	07:43	11:20	217	8	8	8	1736	5.5	100	0.002	0.002	N/A
Area	009	7 - southwest area of South wall - level 10	07:44	11:21	217	8	8	8	1736	4	100	0.002	<LOD	N/A
Area	010	7 - west wall level 10	07:45	11:22	217	8	8	8	1736	3.5	100	0.002	<LOD	N/A
Area	011	7 - decon on ground level, west wall	11:05	13:50	165	8	8	8	1320	4	100	0.002	<LOD	N/A

ASBESTOS AIR SAMPLE RESULTS

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	012	7 - northwest corner , ground level of remaining building	11:07	13:52	165	8	8	8	1320	4.5	100	0.002	0.002	N/A
Area	013	7 - loadout on ground level	11:08	13:53	165	8	8	8	1320	6.5	100	0.002	0.002	N/A
Area	014	7 - Turbine Hall 3 roof at decon	11:14	13:59	165	8	8	8	1320	3	100	0.002	<LOD	N/A
Area	015	7 - east area adjacent east wall stairs - level 10	11:19	14:04	165	8	8	8	1320	2.5	100	0.002	<LOD	N/A
Area	016	7 - southeast area of South wall - level 10	11:20	14:05	165	8	8	8	1320	4	100	0.002	<LOD	N/A
Area	017	7 - southwest area of South wall - level 10	11:21	14:06	165	8	8	8	1320	3.5	100	0.002	<LOD	N/A
Area	018	7 - west wall level 10	11:22	14:07	165	8	8	8	1320	4.5	100	0.002	0.002	N/A
Field Blank	001	Field Blank 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A
Field Blank	002	Field Blank 2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A

Analysis Information

Analyst	David Adams	Analysis Date	11/16/2023
Analyst Signature			

ASBESTOS AIR SAMPLE RESULTS


Project Name	776 Summer Street (#7 Amendment #7 - Level 9)(Power Plant)	Sample Date	11/17/2023
TRC Project #	474824	Sampling Technician	David Adams
Client	HRP 776 Summer Street PropCo LLC	Laboratory	TRC
Facility Name	Building 4 South Wall	Sample/Analysis Method	NIOSH 7400
Facility Location	776 Summer Street, Boston, Massachusetts	Sampling Type	PCM

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	003	7 - decon on ground level, west wall	07:30	10:40	190	8	8	8	1520	8	100	0.002	0.003	N/A
Area	004	7 - northwest corner , ground level of remaining building	07:32	10:42	190	8	8	8	1520	5.5	100	0.002	0.002	N/A
Area	005	7 - loadout on ground level	07:33	10:43	190	8	8	8	1520	9	100	0.002	0.003	N/A
Area	006	7 - Turbine Hall 3 roof at decon	07:38	10:49	191	8	8	8	1528	6.5	100	0.002	0.002	N/A
Area	007	7 - east area adjacent east wall stairs - level 09	07:43	10:54	191	8	8	8	1528	4	100	0.002	<LOD	N/A
Area	008	7 - southeast area of South wall - level 09	07:44	10:55	191	8	8	8	1528	4.5	100	0.002	<LOD	N/A
Area	009	7 - southwest area of South wall - level 09	07:45	10:56	191	8	8	8	1528	3.5	100	0.002	<LOD	N/A
Area	010	7 - west wall level 09	07:46	10:57	191	8	8	8	1528	5	100	0.002	0.002	N/A
Area	011	7 - decon on ground level	10:40	13:30	170	8	8	8	1360	6	100	0.002	0.002	N/A

ASBESTOS AIR SAMPLE RESULTS

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	012	7 - northwest corner , ground level of remaining building	10:42	13:32	170	8	8	8	1360	4.5	100	0.002	<0.002	N/A
Area	013	7 - loadout on ground level	10:43	13:33	170	8	8	8	1360	7	100	0.002	0.003	N/A
Area	014	7 - Turbine Hall 3 roof at decon	10:49	13:39	170	8	8	8	1360	5	100	0.002	<0.002	N/A
Area	015	7 - east area adjacent east wall stairs - level 09	10:54	13:44	170	8	8	8	1360	6	100	0.002	0.002	N/A
Area	016	7 - southeast area of South wall - level 09	10:55	13:45	170	8	8	8	1360	3.5	100	0.002	<0.002	N/A
Area	017	7 - southwest area of South wall - level 09	10:56	13:46	170	8	8	8	1360	4.5	100	0.002	<0.002	N/A
Area	018	7 - west wall level 09	10:57	13:47	170	8	8	8	1360	5.5	100	0.002	0.002	N/A
Field Blank	001	Field Blank 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A
Field Blank	002	Field Blank 2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A

Analysis Information

Analyst	David Adams	Analysis Date	11/17/2023
Analyst Signature			

ASBESTOS AIR SAMPLE RESULTS


Project Name	776 Summer Street (#7 Amendment - Level 9 East)(Power Plant)	Sample Date	11/20/2023
TRC Project #	474824	Sampling Technician	David Adams
Client	HRP 776 Summer Street PropCo LLC	Laboratory	TRC
Facility Name	Building 4 South Wall	Sample/Analysis Method	NIOSH 7400
Facility Location	776 Summer Street, Boston, Massachusetts	Sampling Type	PCM

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	003	7 - decon on ground level, west wall	07:25	10:37	192	8	8	8	1536	6.5	100	0.002	0.002	N/A
Area	004	7 - northwest corner , ground level of remaining building	07:27	10:39	192	8	8	8	1536	4.5	100	0.002	<LOD	N/A
Area	005	7 - loadout on ground level	07:28	10:40	192	8	8	8	1536	4	100	0.002	<LOD	N/A
Area	006	7 - Turbine Hall 3 roof at decon	07:33	10:46	193	8	8	8	1544	6	100	0.002	0.002	N/A
Area	007	7 - east area adjacent east wall stairs - level 09	07:38	10:51	193	8	8	8	1544	7	100	0.002	0.002	N/A
Area	008	7 - southeast area of South wall - level 09	07:39	10:52	193	8	8	8	1544	3.5	100	0.002	<LOD	N/A
Area	009	7 - southwest area of South wall - level 09	07:40	10:53	193	8	8	8	1544	2	100	0.002	<LOD	N/A
Area	010	7 - west wall level 09	07:41	10:54	193	8	8	8	1544	4.5	100	0.002	<LOD	N/A
Area	011	7 - decon on ground level, west wall	10:37	13:35	178	8	8	8	1424	6	100	0.002	0.002	N/A

ASBESTOS AIR SAMPLE RESULTS

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	012	7 - northwest corner , ground level of remaining building	10:39	13:37	178	8	8	8	1424	3.5	100	0.002	<LOD	N/A
Area	013	7 - loadout on ground level	10:40	13:38	178	8	8	8	1424	6	100	0.002	0.002	N/A
Area	014	7 - Turbine Hall 3 roof at decon	10:46	13:44	178	8	8	8	1424	4	100	0.002	<LOD	N/A
Area	015	7 - east area adjacent east wall stairs - level 09	10:51	13:49	178	8	8	8	1424	5.5	100	0.002	0.002	N/A
Area	016	7 - southeast area of South wall - level 09	10:52	13:50	178	8	8	8	1424	3	100	0.002	<LOD	N/A
Area	017	7 - southwest area of South wall - level 09	10:53	13:51	178	8	8	8	1424	6.5	100	0.002	0.002	N/A
Area	018	7 - west wall level 09	10:54	13:52	178	8	8	8	1424	4.5	100	0.002	0.002	N/A
Field Blank	001	Field Blank 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A
Field Blank	002	Field Blank 2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A

Analysis Information

Analyst	David Adams	Analysis Date	11/20/2023
Analyst Signature			


ASBESTOS AIR SAMPLE RESULTS

Project Name	776 Summer Street (#7 Amendment - Level 9 East)(Power Plant)	Sample Date	11/21/2023
TRC Project #	474824	Sampling Technician	David Adams
Client	HRP 776 Summer Street PropCo LLC	Laboratory	TRC
Facility Name	Building 4 South Wall	Sample/Analysis Method	NIOSH 7400
Facility Location	776 Summer Street, Boston, Massachusetts	Sampling Type	PCM

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	003	7 - decon on ground level, west wall	07:32	10:33	181	8	8	8	1448	5	100	0.002	0.002	N/A
Area	004	7 - northwest corner , ground level of remaining building	07:34	10:35	181	8	8	8	1448	4	100	0.002	<LOD	N/A
Area	005	7 - loadout on ground level	07:35	10:36	181	8	8	8	1448	6.5	100	0.002	0.002	N/A
Area	006	7 - Turbine Hall 3 roof at decon	07:40	10:41	181	8	8	8	1448	3	100	0.002	<LOD	N/A
Area	007	7 - east area adjacent east wall stairs - level 09	07:45	10:46	181	8	8	8	1448	2.5	100	0.002	<LOD	N/A
Area	008	7 - southeast area of South wall - level 09	07:46	10:47	181	8	8	8	1448	5	100	0.002	0.002	N/A
Area	009	7 - southwest area of South wall - level 09	07:47	10:48	181	8	8	8	1448	3	100	0.002	<LOD	N/A
Area	010	7 - west wall level 09	07:50	10:49	179	8	8	8	1432	7	100	0.002	0.002	N/A
Area	011	7 - decon on ground level, west wall	10:33	13:37	184	8	8	8	1472	4	100	0.002	<LOD	N/A

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	012	7 - northwest corner , ground level of remaining building	10:35	13:39	184	8	8	8	1472	6.5	100	0.002	0.002	N/A
Area	013	7 - loadout on ground level	10:36	13:40	184	8	8	8	1472	5	100	0.002	0.002	N/A
Area	014	7 - Turbine Hall 3 roof at decon	10:41	13:46	185	8	8	8	1480	3.5	100	0.002	<LOD	N/A
Area	015	7 - east area adjacent east wall stairs - level 09	10:46	13:51	185	8	8	8	1480	5	100	0.002	0.002	N/A
Area	016	7 - southeast area of South wall - level 09	10:47	13:52	185	8	8	8	1480	6	100	0.002	0.002	N/A
Area	017	7 - southwest area of South wall - level 09	10:48	13:53	185	8	8	8	1480	4	100	0.002	<LOD	N/A
Area	018	7 - west wall level 09	10:49	13:54	185	8	8	8	1480	5.5	100	0.002	0.002	N/A
Field Blank	001	Field Blank 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A
Field Blank	002	Field Blank 2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A

Analysis Information

Analyst	David Adams	Analysis Date	11/21/2023
Analyst Signature			

ASBESTOS AIR SAMPLE RESULTS


Project Name	776 Summer Street (#7 Amendment - Level 9 East)(Power Plant)	Sample Date	11/22/2023
TRC Project #	474824	Sampling Technician	David Adams
Client	HRP 776 Summer Street PropCo LLC	Laboratory	TRC
Facility Name	Building 4 South Wall	Sample/Analysis Method	NIOSH 7400
Facility Location	776 Summer Street, Boston, Massachusetts	Sampling Type	PCM

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	003	7 - decon on ground level, west wall	07:25	09:30	125	10	10	10	1250	1.5	100	0.002	<LOD	N/A
Area	004	7 - northwest corner , ground level of remaining building	07:27	09:32	125	10	10	10	1250	2	100	0.002	<LOD	N/A
Area	005	7 - loadout on ground level	07:28	09:33	125	10	10	10	1250	4.5	100	0.002	0.002	N/A
Area	006	7 - Turbine Hall 3 roof at decon	07:34	09:40	126	10	10	10	1260	1	100	0.002	<LOD	N/A
Area	007	7 - decon on ground level, west wall	09:30	11:35	125	10	10	10	1250	1	100	0.002	<LOD	N/A
Area	008	7 - northwest corner , ground level of remaining building	09:32	11:37	125	10	10	10	1250	3.5	100	0.002	<LOD	N/A
Area	009	7 - loadout on ground level	09:33	11:38	125	10	10	10	1250	5	100	0.002	0.002	N/A
Area	010	7 - Turbine Hall 3 roof at decon	09:40	11:45	125	10	10	10	1250	1.5	100	0.002	<LOD	N/A

ASBESTOS AIR SAMPLE RESULTS

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Field Blank	001	Field Blank 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A
Field Blank	002	Field Blank 2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	2	N/A	N/A	N/A

Analysis Information

Analyst	David Adams	Analysis Date	11/22/2023
Analyst Signature			


Project Name	776 Summer Street (#7 Amendment - Level 9 West) (Power Plant)	Sample Date	11/27/2023
TRC Project #	474824	Sampling Technician	Jeremy Faulkner
Client	HRP 776 Summer Street PropCo LLC	Laboratory	TRC
Facility Name	Building 4 South Wall	Sample/Analysis Method	NIOSH 7400
Facility Location	776 Summer Street, Boston, Suffolk County, MA 02127 US	Sampling Type	PCM

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	003	7 - decon on ground level, west wall	07:24	10:32	188	8	8	8	1504	2	100	0.002	<LOD	N/A
Area	004	7 - northwest corner, ground level of remaining building	07:25	10:33	188	8	8	8	1504	4	100	0.002	<LOD	N/A
Area	005	7 - loadout on ground level	07:26	10:34	188	8	8	8	1504	3.5	100	0.002	<LOD	N/A
Area	006	7 - Turbine Hall 3 roof at decon	07:32	10:42	190	8	8	8	1520	5	100	0.002	0.002	N/A
Area	007	7 - east area adjacent east wall stairs level 09	07:33	10:43	190	8	8	8	1520	6.5	100	0.002	0.002	N/A
Area	008	7 - southeast area of South wall level 09	07:34	10:44	190	8	8	8	1520	8	100	0.002	0.003	N/A
Area	009	7 - southwest area of South wall - level 09	07:35	10:45	190	8	8	8	1520	5	100	0.002	0.002	N/A
Area	010	7 - west wall at corner level 09	07:36	10:46	190	8	8	8	1520	7.5	100	0.002	0.002	N/A
Area	011	7 - decon on ground level, west wall	10:32	13:47	195	8	8	8	1560	3	100	0.002	<LOD	N/A

ASBESTOS AIR SAMPLE RESULTS

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	012	7 - northwest corner, ground level of remaining building	10:33	13:48	195	8	8	8	1560	5	100	0.002	0.002	N/A
Area	013	7 - loadout on ground level	10:34	13:49	195	8	8	8	1560	1.5	100	0.002	<LOD	N/A
Area	014	7 - Turbine Hall 3 roof at decon	10:42	13:54	192	8	8	8	1536	4	100	0.002	<LOD	N/A
Area	015	7 - east area adjacent east wall stairs level 09	10:43	13:55	192	8	8	8	1536	3	100	0.002	<LOD	N/A
Area	016	7 - southeast area of South wall level 09	10:44	13:56	192	8	8	8	1536	6	100	0.002	0.002	N/A
Area	017	7 - southwest area of South wall - level 09	10:45	13:57	192	8	8	8	1536	4	100	0.002	<LOD	N/A
Area	018	7 - west wall at corner level 09	10:46	13:58	192	8	8	8	1536	5.5	100	0.002	0.002	N/A
Field Blank	001	Field Blank 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A
Field Blank	002	Field Blank 2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A

Analysis Information

Analyst	Jeremy Faulkner	Analysis Date	11/27/2023
Analyst Signature			


Project Name	776 Summer Street (#7 Amendment - Level 9 West) (Power Plant)	Sample Date	11/28/2023
TRC Project #	474824	Sampling Technician	Jeremy Faulkner
Client	HRP 776 Summer Street PropCo LLC	Laboratory	TRC
Facility Name	Building 4 South Wall	Sample/Analysis Method	NIOSH 7400
Facility Location	776 Summer Street, Boston, Suffolk County, MA 02127 US	Sampling Type	PCM

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	003	7 - decon on ground level, west wall	07:28	10:47	199	8	8	8	1592	1	100	0.002	<LOD	N/A
Area	004	7 - northwest corner, ground level of remaining building	07:29	10:48	199	8	8	8	1592	3	100	0.002	<LOD	N/A
Area	005	7 - loadout on ground level	07:30	10:49	199	8	8	8	1592	6	100	0.002	0.002	N/A
Area	006	7 - Turbine Hall 3 roof at decon	07:35	10:54	199	8	8	8	1592	2	100	0.002	<LOD	N/A
Area	007	7 - east area adjacent east wall stairs level 09	07:36	10:55	199	8	8	8	1592	3.5	100	0.002	<LOD	N/A
Area	008	7 - southeast area of South wall level 09	07:37	10:56	199	8	8	8	1592	5	100	0.002	0.002	N/A
Area	009	7 - southwest area of South wall - level 09	07:38	10:57	199	8	8	8	1592	8.5	100	0.002	0.003	N/A
Area	010	7 - west wall at corner level 09	07:39	10:58	199	8	8	8	1592	4.5	100	0.002	<LOD	N/A
Area	011	7 - decon on ground level, west wall	10:47	13:46	179	8	8	8	1432	3.5	100	0.002	<LOD	N/A

ASBESTOS AIR SAMPLE RESULTS

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	012	7 - northwest corner, ground level of remaining building	10:48	13:47	179	8	8	8	1432	2.5	100	0.002	<LOD	N/A
Area	013	7 - loadout on ground level	10:49	13:48	179	8	8	8	1432	4	100	0.002	<LOD	N/A
Area	014	7 - Turbine Hall 3 roof at decon	10:54	13:53	179	8	8	8	1432	2	100	0.002	<LOD	N/A
Area	015	7 - east area adjacent east wall stairs level 09	10:55	13:54	179	8	8	8	1432	6	100	0.002	0.002	N/A
Area	016	7 - southeast area of South wall level 09	10:57	13:55	178	8	8	8	1424	5	100	0.002	0.002	N/A
Area	017	7 - southwest area of South wall - level 09	10:58	13:56	178	8	8	8	1424	7	100	0.002	0.002	N/A
Area	018	7 - west wall at corner level 09	10:59	13:57	178	8	8	8	1424	6	100	0.002	0.002	N/A
Field Blank	001	Field Blank 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A
Field Blank	002	Field Blank 2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A

Analysis Information

Analyst	Jeremy Faulkner	Analysis Date	11/28/2023
Analyst Signature			


Project Name	776 Summer Street (#7 Amendment - Level 9 West) (Power Plant)	Sample Date	11/29/2023
TRC Project #	474824	Sampling Technician	Jeremy Faulkner
Client	HRP 776 Summer Street PropCo LLC	Laboratory	TRC
Facility Name	Building 4 South Wall	Sample/Analysis Method	NIOSH 7400
Facility Location	776 Summer Street, Boston, Suffolk County, MA 02127 US	Sampling Type	PCM

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	003	7 - decon on ground level, west wall	07:30	10:44	194	8	8	8	1552	3	100	0.002	<LOD	N/A
Area	004	7 - northwest corner, ground level of remaining building	07:31	10:45	194	8	8	8	1552	6.5	100	0.002	0.002	N/A
Area	005	7 - loadout on ground level	07:32	10:46	194	8	8	8	1552	9	100	0.002	0.003	N/A
Area	006	7 - Turbine Hall 3 roof at decon	07:36	10:51	195	8	8	8	1560	4	100	0.002	<LOD	N/A
Area	007	7 - east area adjacent east wall stairs level 09	07:37	10:52	195	8	8	8	1560	2.5	100	0.002	<LOD	N/A
Area	008	7 - southeast area of South wall level 09	07:38	10:53	195	8	8	8	1560	1.5	100	0.002	<LOD	N/A
Area	009	7 - southwest area of South wall	07:39	10:54	195	8	8	8	1560	5	100	0.002	0.002	N/A
Area	010	7 - west wall at corner level 09	07:40	10:55	195	8	8	8	1560	4.5	100	0.002	<LOD	N/A
Area	011	7 - decon on ground level, west wall	10:44	13:42	178	8	8	8	1424	1.5	100	0.002	<LOD	N/A

ASBESTOS AIR SAMPLE RESULTS

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	012	7 - northwest corner, ground level of remaining building	10:45	13:43	178	8	8	8	1424	4	100	0.002	<LOD	N/A
Area	013	7 - loadout on ground level	10:46	13:44	178	8	8	8	1424	5.5	100	0.002	0.002	N/A
Area	014	7 - Turbine Hall 3 roof at decon	10:47	13:45	178	8	8	8	1424	3	100	0.002	<LOD	N/A
Field Blank	001	Field Blank 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A
Field Blank	002	Field Blank 2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A

Analysis Information

Analyst	Jeremy Faulkner	Analysis Date	11/29/2023
Analyst Signature			

ASBESTOS AIR SAMPLE RESULTS

Project Name	776 Summer Street (#7 Amendment - Level 8) (Power Plant)	Sample Date	11/30/2023
TRC Project #	474824	Sampling Technician	Jeremy Faulkner
Client	HRP 776 Summer Street PropCo LLC	Laboratory	TRC
Facility Name	Building 4 South Wall	Sample/Analysis Method	NIOSH 7400
Facility Location	776 Summer Street, Boston, Suffolk County, MA 02127 US	Sampling Type	PCM

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	003	7 - decon on ground level, west wall	07:35	10:45	190	8	8	8	1520	2	100	0.002	<LOD	N/A
Area	004	7 - northwest corner, ground level of remaining building	07:36	10:46	190	8	8	8	1520	6.5	100	0.002	0.002	N/A
Area	005	7 - loadout on ground level	07:37	10:47	190	8	8	8	1520	5	100	0.002	0.002	N/A
Area	006	7 - Turbine Hall 3 roof at decon	07:42	10:52	190	8	8	8	1520	3	100	0.002	<LOD	N/A
Area	007	7 - near SE stairs of scaffolding level 08	07:43	10:53	190	8	8	8	1520	2.5	100	0.002	<LOD	N/A
Area	008	7 - southeast area of South wall level 08	07:44	10:54	190	8	8	8	1520	4	100	0.002	<LOD	N/A
Area	009	7 - south center of south wall level 08	07:45	10:55	190	8	8	8	1520	9.5	100	0.002	0.003	N/A
Area	010	7 - SW corner of scaffolding by west wall level 08	07:46	10:56	190	8	8	8	1520	7	100	0.002	0.002	N/A
Area	011	7 - decon on ground level, west wall	10:45	13:51	186	8	8	8	1488	1.5	100	0.002	<LOD	N/A

ASBESTOS AIR SAMPLE RESULTS

Sample Type	Sample #	Sample Location	Time On	Time Off	Total Time	Pre (L/m)	Post (L/m)	Avg (L/m)	Total Volume (L)	Total Fibers	Total Fields	LOD (f/cc)	Results (f/cc)	Notes
Area	012	7 - northwest corner, ground level of remaining building	10:46	13:52	186	8	8	8	1488	5	100	0.002	0.002	N/A
Area	013	7 - loadout on ground level	10:47	13:53	186	8	8	8	1488	3	100	0.002	<LOD	N/A
Area	014	7 - Turbine Hall 3 roof at decon	10:52	13:58	186	8	8	8	1488	2.5	100	0.002	<LOD	N/A
Area	015	7 - near SE stairs of scaffolding level 08	10:53	13:59	186	8	8	8	1488	4	100	0.002	<LOD	N/A
Area	016	7 - southeast area of South wall level 08	10:54	14:00	186	8	8	8	1488	5.5	100	0.002	0.002	N/A
Area	017	7 - south center of south wall level 08	10:55	14:01	186	8	8	8	1488	6.5	100	0.002	0.002	N/A
Area	018	7 - SW corner of scaffolding by west wall level 08	10:56	14:02	186	8	8	8	1488	8	100	0.002	0.003	N/A
Field Blank	001	Field Blank 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A
Field Blank	002	Field Blank 2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	100	N/A	N/A	N/A

Analysis Information

Analyst	Jeremy Faulkner	Analysis Date	11/30/2023
Analyst Signature	